

December 19, 2012

IOWA UTILITIES BOARD

**ITC Midwest LLC Deficiency Response to Deficiency Letter Dated December 18, 2012**

**File: E-20994, AM11**

**Central City Terrace Sub to Coggon**

**Linn County**

1. Exhibit A
  - a. Changed spelling of Coggon to Coggon.
  - b. Revised as suggested.
2. Exhibit B
  - a. Moved box to the right of R6W
  - b. None of the taps are shown because we do not interpret the rule as requiring them. Underbuilds have been shown but we do not consider taps to be underbuild. If we have interpreted this rule incorrectly for abbreviated process filings, please let us know.
  - c. Same response as item b. above.
  - d. Inserted section line between Sections 34 and 35.
  - e. Inserted section line into symbol legend.
3. Exhibit C – Segment 1 of 3
  - a. Revised as suggested.
  - b. Updated the third column for the strain insulator. The same insulator is used for both heavy angles and deadends.
  - c. Line 44 has been changed to reflect “N/A”.
4. Exhibit C – Segment 2 of 3
  - a. Revised as suggested.
5. Exhibit C – Segment 3 of 3
  - a. Revised as suggested.
  - b. Revised as suggested.
  - c. The dimension has been revised.
  - d. Underbuild drawings have been included.
6. Exhibit F
  - a. Zip code has been corrected and notification letter has been resent.
  - b. First: PO Box number has been corrected and notification letter has been resent.  
Second: Revised as suggested.
  - c. Windstream Communications has been added to the notification list and letter has been sent. Alliant Energy Corporation has been addressed under Interstate Power and Light Company.
  - d. Ownership has been identified as Interstate Power and Light Company and notification letter was previously sent.
  - e. Ownership has been identified as Farmers Mutual Telephone Cooperative of Shellsburg and notification letter was previously sent.
  - f. Re-addressed letter has been provided.