

January 28, 2013

IOWA UTILITIES BOARD

ITC Midwest LLC Response to Deficiency Letter Dated January 17, 2013

File No.: E-20994, Amendment 10

Hiawatha - Lafayette

Linn County

1. **Exhibit A**

**First:** Revised as suggested. **Second:** Revised as suggested. **Third:** Revised as suggested.

2. **Exhibit C – Segment 1 of 3**

Revised as suggested.

3. **Exhibit C – Segment 2 of 3**

a. **First:** Township and range corrected. **Second:** Conductor temperature has been indicated. **Third:** Conductor temperature of underbuild has been indicated. **Fourth:** Vertical separation has been indicated. **Fifth:** The distribution line does not attach to any structures south of distribution inset 49.1. It attaches to structures 50 and 51 and then leaves the transmission line.

b. Revised clearance drawings as suggested.

RECEIVED  
January 28, 2013

E-20994  
(Amendment No. 10)